

TABELA ANKER BLOKOVA ZA GLAVNI TRANSPORTNI VOD

 EU funded project Projekat finansira Europska Unija		 WYG International part of the WYG group creative minds safe hands 					
Client/Klient		Consultant/Konsultant					
INFRASTRUCTURE PROJECTS FACILITY IN THE WESTERN BALKANS		WYG INTERNATIONAL UK	 INSTITUT ZA HIDROTEHNIKU GRAĐEVINSKOG FAKULTETA U SARAJEVU				
Project/Projekat							
REGIONALNI SISTEM VODOSNABDIJEVANJA PLAVA VODA							
Project status/Tip Projekta GLAVNI PROJEKT	Drawing date /Datum crteža: 11.06.2011. Drawing approved/Crtež odobren: 23.11.2011.	Drawing status /Status Crteža FINAL Drawing approved/Crtež odobren: 23.11.2011.	Drawing scale/Mjerilo crteža (Priloga) Format A3(420/297 mm)				
Drawing name/Ime Priloga TABELA ANKER BLOKOVA ZA GLAVNI TRANSPORTNI VOD	Prepared by:  INSTITUT ZA HIDROTEHNIKU GRAĐEVINSKOG FAKULTETA U SARAJEVU Šestina Tomića 1, Sarajevo, Bosna i Hercegovina Tel./fax: 31 24 66637, 20 44 95; E-mail: hte@instit.com.ba ID broj: 400000810003, ID broj: 30000810003, ID broj: 400000810003, ID broj: 400000810003		Drawing no/ Prilog broj 2A.31				
			<table><tr><td>Sheet/List</td><td>Of/Ofd</td></tr><tr><td>1</td><td>13</td></tr></table>	Sheet/List	Of/Ofd	1	13
Sheet/List	Of/Ofd						
1	13						

TABELA ANKER BLOKOVA OD IZVORIŠTA PLAVA VODA DO ODVOJKA DOLAC NA LAŠVI

Tjeme	Stacionaža	α -hor	α -ver	$\sin(\alpha\text{-hor}/2)$	$\sin(\alpha\text{-ver})/2$	ϕ (mm)	N (kN)	$R = 2 \cdot N \cdot \sin(\alpha\text{-hor})/2$ (kN)	$R = 2 \cdot N \cdot \sin(\alpha\text{-ver})/2$ (kN)	$\text{potA} = R/\sigma$ (m ²)	Usvojena dužina (A)	Usvojena širina (V)/visina (H) = (B)	Usvojena površina axb	a'	x	y	a''	Vbr	V m ³	L	Tip bloka
T1	0+008.71	11	-69.40																		
T2	0+009.41		68.50	0.00	0.56	700	384.84	0.00	433.18	2.89	2.1	1.4	2.94	0.33	1.12	0.00	0	0.00	1.90		v1
T4	0+025.96	3	-30.50	0.03	-0.26	700	384.84	20.15	-202.45		2.40	1.85	4.44	2.40				10.64	9.72	2.4	v2
T5	0+027.08		23.60	0.00	0.20	700	384.84	0.00	157.40	1.05	0.9	1.4	1.26	0.82	0.88	0.00	0	0.00	1.06		v1
T11	0+166.54	29		0.25	0.00	700	384.84	192.71	0.00	1.28	1	1.4	1.4	0.79	0.92	0.48	0.53	1.50	0.94		H
T12	0+195.13	90	0.00	0.71	0.00	700	38.48	54.42	0.00	0.36	0.9	1.4	1.26	0.00	1.15	0.25	0.2	1.08			prostorni
		0	-28.70	0.00	-0.25	700	38.48	0.00	-19.07		1.40	1.85	2.59	0.76				1.08	0.92	0.42	
T13	0+195.76		26.50	0.00	0.23	700	384.84	0.00	176.41	1.18	0.9	1.4	1.26	0.81	0.90	0.00	0	0.00	1.08		v1
T17	0+232.84	15		0.13	0.00	700	384.84	100.46	0.00	0.67	0.9	1.4	1.26	0.87	0.82	0.58	0.65	1.52			Most-prostorni
			33.20	0.00	0.29	700	384.84	0.00	219.89	1.47	1.1	1.4	1.54	0.75	0.95	0.00	0	0.00	1.23		
T20	0+249.53		28.10	0.00	0.24	700	384.84	0.00	186.85	1.25	0.9	1.4	1.26	0.79	0.91	0.00	0	0.00	1.08		v1
T29	0+335.12	49		0.41	0.00	700	384.84	319.18	0.00	2.13	1.6	1.4	2.24	0.59	1.04	0.36	0.56	2.12	1.63		H
T30	0+337.48		38.10	0.00	0.33	700	384.84	0.00	251.22	1.67	1.2	1.4	1.68	0.71	0.98	0.00	0	0.00	1.31		v1
T33	0+372.52	35		0.30	0.00	700	384.84	231.45	0.00	1.54	1.2	1.4	1.68	0.74	0.96	0.44	0.56	1.72			Most-prostorni
			32.00	0.00	0.28	700	384.84	0.00	212.15	1.41	1.1	1.4	1.54	0.76	0.94	0.00	0	0.00	1.22		
T34	0+376.82	50		0.42	0.00	700	384.84	325.28	0.00	2.17	1.6	1.4	2.24	0.58	1.04	0.36	0.55	2.11	1.63		H
T35	0+382.93	90		0.71	0.00	700	384.84	544.25	0.00	3.63	2.6	1.4	3.64	0.00	1.15	0.25	0.57	3.11	2.72		H
T36	0+406.24	24		0.21	0.00	700	384.84	160.03	0.00	1.07	0.9	1.4	1.26	0.82	0.88	0.52	0.53	1.40	0.82		H
T77	0+885.53	68		0.56	0.00	700	384.84	430.40	0.00	2.87	2.1	1.4	2.94	0.34	1.12	0.28	0.54	2.59	2.16		H
T78	0+901.14	79		0.64	0.00	700	384.84	489.58	0.00	3.26	2.4	1.4	3.36	0.17	1.14	0.26	0.55	2.89	2.48		H
T80	0+930.03	17		0.15	0.00	700	384.84	113.77	0.00	0.76	0.9	1.4	1.26	0.86	0.83	0.57	0.62	1.49	0.85		H
Ukupno:																			32.75		

V1-vertikalni lom sa rezultantom prema dole
V2-vertikalni lom sa rezultantom prema gore
H-horizontalni lom

TABELA ANKER BLOKOVA OD ODVOJKA DOLAC NA LAŠVI DO ODVOJAKA NOVA BILA I NOVI TRAVNIK

Tjeme	Stacionaža	α -hor	α -ver	$\sin(\alpha\text{-hor}/2)$	$\sin(\alpha\text{-ver})/2$	ϕ (mm)	N (kN)	$R = 2 * N * \sin(\alpha\text{-hor})/2$ (kN)	$R = 2 * N * \sin(\alpha\text{-ver})/2$ (kN)	potA= R/ σ (m2)	Usvojena dužina (A)	Usvojena širina (V)/visina (H) = (B)	Usvojena površina axb	a'	x	y	a''	Vbr	V m3	L	Tip bloka
T108	1+305.69	83		0.66	0.00	700	384.84	510.01	0.00	3.40	2.5	1.4	3.5	0.11	1.15	0.25	0.56	3.00	2.60		H
T109	1+312.41	87		0.69	0.00	700	384.84	529.81	0.00	3.53	2.6	1.4	3.64	0.05	1.15	0.25	0.57	3.11	2.71		H
T118	1+417.55	18		0.16	0.00	700	384.84	120.40	0.00	0.80	0.9	1.4	1.26	0.86	0.84	0.56	0.61	1.48	0.85		H
T123	1+460.49	6	30.20	0.05	0.26	700	384.84	40.28	200.51	1.34	1	1.4	1.4	0.78	0.93	0.00	0	0.00	1.15		v1
T124	1+465.17		-31.70																		Mostovski
T125	1+492.98		-32.10																		Mostovski
T126	1+496.85	20		0.17	0.00	700	384.84	133.65	0.00	0.89	0.9	1.4	1.26	0.85	0.85	0.55	0.58	1.45			prostorni
			32.40	0.00	0.28	700	384.84	0.00	214.73	1.43	1.1	1.4	1.54	0.76	0.94	0.00	0	0.00	1.23		
T127	1+517.87	83		0.66	0.00	700	384.84	510.01	0.00	3.40	2.5	1.4	3.5	0.11	1.15	0.25	0.56	3.00	2.60		H
T143	1+940.76		15.20	0.00	0.13	700	384.84	0.00	101.80	0.68	0.9	1.4	1.26	0.87	0.82	0.00	0	0.00	1.01		v1
T145	1+952.65		-13.60	0.00	-0.12	700	384.84	0.00	-91.13		1.55	2.06	3.20	1.55				4.98	4.38	1.55	v2
T161	2+326.37		-10.60	0.00	-0.09	700	384.84	0.00	-71.10		1.40	2.01	2.82	1.40				3.96	3.42	1.4	v2
T163	2+354.80	32	-4.30	0.28	-0.04	700	384.84	212.15	-28.88	1.41	1.1	1.4	1.54	0.76	0.94	0.46	0.55	1.62	1.06		H
T164	2+381.86	33	5.40	0.28	0.05	700	384.84	218.60	36.26	1.46	1.1	1.4	1.54	0.75	0.95	0.45	0.53	1.60	1.05		H
T172	2+651.96	27	-4.00	0.23	-0.03	700	384.84	179.68	-26.86	1.20	0.9	1.4	1.26	0.80	0.90	0.50	0.5	1.37	0.80		H
T173	2+666.74	28		0.24	0.00	700	384.84	186.20	0.00	1.24	0.9	1.4	1.26	0.79	0.91	0.49	0.49	1.36	0.80		H
T184	2+842.59	17		0.15	0.00	700	384.84	113.77	0.00	0.76	0.9	1.4	1.26	0.86	0.83	0.57	0.62	1.49			prostorni
			-5.10	0.00	-0.04	700	384.84	0.00	-34.24		1.40	1.85	2.59	1.02				1.94	1.65	0.75	prostorni
T186	2+851.99	18		0.16	0.00	700	384.84	120.40	0.00	0.80	0.9	1.4	1.26	0.86	0.84	0.56	0.61	1.48	0.85		H
T187	2+859.79	20	5.10	0.17	0.04	700	384.84	133.65	34.24	0.89	0.9	1.4	1.26	0.85	0.85	0.55	0.58	1.45	0.84		H
T203	3+197.62		-6.20	0.00	-0.05	700	384.84	0.00	-41.62		1.40	2.01	2.81	1.07				2.32	2	0.82	v2
T235	3+795.92	16		0.14	0.00	700	384.84	107.12	0.00	0.71	0.9	1.4	1.26	0.87	0.82	0.58	0.63	1.50			Most-prostorni
			-18.30	0.00	-0.16	700	384.84	0.00	-122.39		1.89	1.85	3.50	1.89				6.61	5.88	1.89	
T236	3+802.27	17		0.15	0.00	700	384.84	113.77	0.00	0.76	0.9	1.4	1.26	0.86	0.83	0.57	0.62	1.49			Most-prostorni
			17.40	0.00	0.15	700	384.84	0.00	116.42	0.78	0.9	1.4	1.26	0.86	0.83	0.00	0	0.00	1.03		
T237	3+816.46	18		0.16	0.00	700	384.84	120.40	0.00	0.80	0.9	1.4	1.26	0.86	0.84	0.56	0.61	1.48			Most-prostorni
			21.70	0.00	0.19	700	384.84	0.00	144.88	0.97	0.9	1.4	1.26	0.84	0.87	0.00	0	0.00	1.05		
T238	3+822.28	18		0.16	0.00	700	384.84	120.40	0.00	0.80	0.9	1.4	1.26	0.86	0.84	0.56	0.61	1.48			Most-prostorni
			-20.20	0.00	-0.18	700	384.84	0.00	-134.98		1.98	1.85	3.66	1.98				7.24	6.48	1.98	
T250	4+111.55	25	-2.70	0.22	-0.02	700	769.68	333.18	-36.27	2.22	1.6	1.4	2.24	0.82	0.89	0.51	0.92	2.47	1.82		H
T252	4+123.89	21		0.18	0.00	700	769.68	280.53	0.00	1.87	1.4	1.4	1.96	0.84	0.86	0.54	0.88	2.23	1.57		H
T264	4+347.48		-3.30	0.00	-0.03	700	769.68	0.00	-44.32		1.40	2.01	2.81	1.11				2.47	2.13	0.88	v2
T289	4+858.39	37		0.32	0.00	700	384.84	244.22	0.00	1.63	1.2	1.4	1.68	0.72	0.97	0.43	0.54	1.71			Most-prostorni
			-16.50	0.00	-0.14	700	384.84	0.00	-110.44		1.80	1.85	3.33	1.80				6.00	5.31	1.8	
T290	4+862.04	33		0.28	0.00	700	384.84	218.60	0.00	1.46	1.1	1.4	1.54	0.75	0.95	0.45	0.53	1.60	1.05		Most-prostorni
			16.40	0.00	0.14	700	384.84	0.00	109.78	0.73	0.9	1.4	1.26	0.86	0.83	0.00	0	0.00			

TABELA ANKER BLOKOVA OD ODVOJKA DOLAC NA LAŠVI DO ODVOJAKA NOVA BILA I NOVI TRAVNIK

Tjeme	Stacionaža	α -hor	α -ver	$\sin(\alpha\text{-hor}/2)$	$\sin(\alpha\text{-ver})/2$	Φ (mm)	N (kN)	$R = 2 * N * \sin(\alpha\text{-hor})/2$ (kN)	$R = 2 * N * \sin(\alpha\text{-ver})/2$ (kN)	potA= R/ σ (m2)	Usvojena dužina (A)	Usvojena širina (V)/visina (H) = (B)	Usvojena površina axb	a'	x	y	a''	Vbr	V m3	L	Tip bloka
T291	4+873.10	34		0.29	0.00	700	384.84	225.03	0.00	1.50	1.1	1.4	1.54	0.75	0.95	0.45	0.52	1.59	1.05		Most-prostorni
			19.00	0.00	0.17	700	384.84	0.00	127.03	0.85	0.9	1.4	1.26	0.85	0.85	0.00	0	0.00			
T292	4+876.71	32		0.28	0.00	700	384.84	212.15	0.00	1.41	1.1	1.4	1.54	0.76	0.94	0.46	0.55	1.62			Most-prostorni
			-19.30	0.00	-0.17	700	384.84	0.00	-129.02		1.94	1.85	3.58	1.94				6.95	6.2	1.94	
T454	8+307.12	12		0.10	0.00	700	769.68	160.91	0.00	1.07	0.9	1.4	1.26	0.88	0.79	0.61	0.69	1.56	0.88		H
Ukupno:																			63.45		

V1-vertikalni lom sa rezultantom prema dole
V2-vertikalni lom sa rezultantom prema gore
H-horizontalni lom

TABELA ANKER BLOKOVA OD ODVOJKA N.TRAVNIK DO ODVOJKA VITEZ

Tjeme	Stacionaža	α -hor	α -ver	$\sin(\alpha\text{-hor}/2)$	$\sin(\alpha\text{-ver})/2$	Φ (mm)	N (kN)	$R = 2 \cdot N \cdot \sin(\alpha\text{-hor})/2$ (kN)	$R = 2 \cdot N \cdot \sin(\alpha\text{-ver})/2$ (kN)	potA= R/ σ (m2)	Usvojena dužina (A)	Usvojena širina (V)/visina (H) = (B)	Usvojena površina axb	a'	x	y	a''	Vbr	V m3	L	Tip bloka
T308	5+248.20	52		0.44	0.00	700	769.68	674.81	0.00	4.50	3.3	1.4	4.62	0.55	1.05	0.35	1.09	4.30			Most-prostorni
			-11.80	0.00	-0.10	700	769.68	0.00	-158.23		2.13	1.85	3.95	2.13				8.42	7.6	2.13	
T309	5+250.88	52		0.44	0.00	700	769.68	674.81	0.00	4.50	3.3	1.4	4.62	0.55	1.05	0.35	1.09	4.30	3.76		Most-prostorni
			12.20	0.00	0.11	700	769.68	0.00	163.58	1.09	0.9	1.4	1.26	0.88	0.80	0.00	0	0.00			
T310	5+262.39	53		0.45	0.00	700	769.68	686.86	0.00	4.58	3.3	1.4	4.62	0.54	1.06	0.34	1.07	4.28	3.75		Most-prostorni
			12.50	0.00	0.11	700	769.68	0.00	167.59	1.12	0.9	1.4	1.26	0.88	0.80	0.00	0	0.00			
T311	5+265.04	52		0.44	0.00	700	769.68	674.81	0.00	4.50	3.3	1.4	4.62	0.55	1.05	0.35	1.09	4.30			Most-prostorni
			-12.50	0.00	-0.11	700	769.68	0.00	-167.59		2.19	1.85	4.06	2.19				8.89	8.05	2.19	
T356	6+108.64	16		0.14	0.00	700	769.68	214.24	0.00	1.43	1.1	1.4	1.54	0.87	0.82	0.58	0.77	1.83			Most-prostorni
			-18.40	0.00	-0.16	700	769.68	0.00	-246.11		2.63	1.85	4.87	2.63				12.83	11.82	2.63	
T357	6+115.86	16		0.14	0.00	700	769.68	214.24	0.00	1.43	1.1	1.4	1.54	0.87	0.82	0.58	0.77	1.83			Most-prostorni
			18.40	0.00	0.16	700	769.68	0.00	246.11	1.64	1.2	1.4	1.68	0.85	0.84	0.00	0	0.00	1.21		
T358	6+133.55	17		0.15	0.00	700	769.68	227.53	0.00	1.52	1.1	1.4	1.54	0.86	0.83	0.57	0.76	1.82			Most-prostorni
			19.20	0.00	0.17	700	769.68	0.00	256.72	1.71	1.3	1.4	1.82	0.85	0.85	0.00	0	0.00	1.28		
T359	6+140.78	17		0.15	0.00	700	769.68	227.53	0.00	1.52	1.1	1.4	1.54	0.86	0.83	0.57	0.76	1.82			Most-prostorni
			-19.10	0.00	-0.17	700	769.68	0.00	-255.39		2.68	1.85	4.96	2.68				13.29	12.26	2.68	
T361	6+165.44	8		0.07	0.00	700	769.68	107.38	0.00	0.72	0.9	1.4	1.26	0.89	0.76	0.64	0.76	1.63	0.92		H
T371	6+453.02	20		0.17	0.00	700	769.68	267.31	0.00	1.78	1.3	1.4	1.82	0.85	0.85	0.55	0.84	2.10	1.43		H
T372	6+459.73		-9.30	0.00	-0.08	700	769.68	0.00	-124.79		1.88	1.90	3.57	1.88				6.72	6	1.88	v2
T373	6+464.62		8.40	0.00	0.07	700	769.68	0.00	112.74	0.75	0.9	1.4	1.26	0.89	0.77	0.00	0	0.00	0.96		V1
T374	6+468.94	14		0.12	0.00	700	769.68	187.60	0.00	1.25	0.9	1.4	1.26	0.87	0.81	0.59	0.66	1.53	0.87		H
T376	6+571.47	26		0.22	0.00	700	769.68	346.28	0.00	2.31	1.7	1.4	2.38	0.81	0.90	0.50	0.96	2.61	1.95		H
T377	6+600.18	51		0.43	0.00	700	769.68	662.71	0.00	4.42	3.2	1.4	4.48	0.57	1.05	0.35	1.07	4.18	3.64		H
T379	6+639.60	10	-2.00	0.09	-0.02	700	769.68	134.16	-26.87	0.89	0.9	1.4	1.26	0.89	0.78	0.62	0.72	1.59	0.90		H
T401	7+310.00	24	2.30	0.21	0.02	700	769.68	320.05	30.89	2.13	1.6	1.4	2.24	0.82	0.88	0.52	0.94	2.49	1.83		H
T403	7+329.81	30		0.26	0.00	700	769.68	398.42	0.00	2.66	1.9	1.4	2.66	0.78	0.93	0.48	0.98	2.82			prostorni
			-8.10	0.00	-0.07	700	769.68	0.00	-108.72		1.79	1.85	3.31	1.79				5.91	5.22	1.79	
T410	7+479.21	11	2.60	0.10	0.02	700	769.68	147.54	34.92	0.98	0.9	1.4	1.26	0.88	0.79	0.61	0.71	1.58	0.89		H
T411	7+487.84	10		0.09	0.00	700	769.68	134.16	0.00	0.89	0.9	1.4	1.26	0.89	0.78	0.62	0.72	1.59	0.90		H
T412	7+502.97	13	3.20	0.11	0.03	700	769.68	174.26	42.98	1.16	0.9	1.4	1.26	0.88	0.80	0.60	0.68	1.55	0.88		H
T414	7+526.16	7	-5.50	0.06	-0.05	700	384.84	46.99	-36.93		1.40	2.11	2.95	0.98				2.05	1.78	0.69	v2
T427	7+832.09	18		0.16	0.00	700	769.68	240.81	0.00	1.61	1.2	1.4	1.68	0.86	0.84	0.56	0.81	1.97			Most-prostorni
			-18.50	0.00	-0.16	700	769.68	0.00	-247.44		2.64	1.85	4.88	2.64				12.90	11.88	2.64	
T428	7+837.93	20		0.17	0.00	700	769.68	267.31	0.00	1.78	1.3	1.4	1.82	0.85	0.85	0.55	0.84	2.10			Most-prostorni
			18.50	0.00	0.16	700	769.68	0.00	247.44	1.65	1.2	1.4	1.68	0.85	0.84	0.00	0	0.00	1.21		
T429	7+847.19	21		0.18	0.00	700	769.68	280.53	0.00	1.87	1.4	1.4	1.96	0.84	0.86	0.54	0.88	2.23			Most-prostorni
			19.20	0.00	0.17	700	769.68	0.00	256.72	1.71	1.3	1.4	1.82	0.85	0.85	0.00	0	0.00	1.28		
T430	7+852.86	20		0.17	0.00	700	769.68	267.31	0.00	1.78	1.3	1.4	1.82	0.85	0.85	0.55	0.84	2.10			Most-prostorni
			-18.10	0.00	-0.16	700	769.68	0.00	-242.14		2.61	1.85	4.83	2.61				12.64	11.63	2.61	
T442	8+083.29	14	-18.00	0.12	-0.16	700	769.68	187.60	-240.81		2.57	1.90	4.88	2.57				12.55	11.56	2.57	v2

TABELA ANKER BLOKOVA OD ODVOJKA N.TRAVNIK DO ODVOJKA VITEZ

Tjeme	Stacionaža	α -hor	α -ver	$\sin(\alpha\text{-hor}/2)$	$\sin(\alpha\text{-ver})/2$	ϕ (mm)	N (kN)	$R = 2 \cdot N \cdot \sin(\alpha\text{-hor})/2$ (kN)	$R = 2 \cdot N \cdot \sin(\alpha\text{-ver})/2$ (kN)	potA= R/ σ (m2)	Usvojena dužina (A)	Usvojena širina (V)/visina (H) = (B)	Usvojena površina axb	a'	x	y	a''	Vbr	V m3	L	Tip bloka
T443	8+090.06	18		0.16	0.00	700	769.68	240.81	0.00	1.61	1.2	1.4	1.68	0.86	0.84	0.56	0.81	1.97			Most-prostorni
			18.80	0.00	0.16	700	769.68	0.00	251.42	1.68	1.2	1.4	1.68	0.85	0.85	0.00	0	0.00	1.21		
T444	8+105.28	19		0.17	0.00	700	769.68	254.07	0.00	1.69	1.3	1.4	1.82	0.85	0.85	0.55	0.86	2.12			Most-prostorni
			19.30	0.00	0.17	700	769.68	0.00	258.04	1.72	1.3	1.4	1.82	0.85	0.85	0.00	0	0.00	1.28		
T445	8+111.78	10	-18.90	0.09	-0.16	700	769.68	134.16	-252.74		2.47	2.15	5.30	2.47				13.09	12.14	2.47	v2
T454	8+307.12	12		0.10	0.00	700	769.68	160.91	0.00	1.07	0.9	1.4	1.26	0.88	0.79	0.61	0.69	1.56	0.88		H
T455	8+311.83	25	0	0.22	0.00	700	769.68	333.18	0.00	2.22	1.6	1.4	2.24	0.82	0.89	0.51	0.92	2.47	1.82		H
T456	8+318.92	30	0	0.26	0.00	700	769.68	398.42	0.00	2.66	1.9	1.4	2.66	0.78	0.93	0.48	0.98	2.82	2.19		H
T457	8+328.12	30	0	0.26	0.00	700	769.68	398.42	0.00	2.66	1.9	1.4	2.66	0.78	0.93	0.48	0.98	2.82	2.19		H
T458	8+335.21	36	0	0.31	0.00	700	769.68	475.69	0.00	3.17	2.3	1.4	3.22	0.73	0.96	0.44	1.04	3.27	2.66		H
T479	8+760.21	16	0	0.14	0.00	700	769.68	214.24	0.00	1.43	1.1	1.4	1.54	0.87	0.82	0.58	0.77	1.83	1.16		H
T480	8+774.58	19	0	0.17	0.00	700	769.68	254.07	0.00	1.69	1.3	1.4	1.82	0.85	0.85	0.55	0.86	2.12	1.44		H
T491	9+049.71	19	0	0.17	0.00	700	769.68	254.07	0.00	1.69	1.3	1.4	1.82	0.85	0.85	0.55	0.86	2.12	1.44		H
T493	9+063.53	51	0	0.43	0.00	700	769.68	662.71	0.00	4.42	3.2	1.4	4.48	0.57	1.05	0.35	1.07	4.18	3.64		H
T495	9+090.43	82	0	0.66	0.00	700	769.68	1009.91	0.00	6.73	4.9	1.4	6.86	0.13	1.15	0.25	1.09	5.87	5.42		H
T523	9+937.22		32.3	0.00	0.28	700	769.68	0.00	428.18	2.85	2.1	1.4	2.94	0.76	0.94	0.00	0	0.00	1.88		Tip V1
T524	9+940.24		-32	0.00	-0.28	700	769.68	0.00	-424.31	0.00			0								Mostovski
T525	9+968.26		-35.9	0.00	-0.31	700	769.68	0.00	-474.41	0.00			0								Mostovski
T526	9+971.14		35.6	0.00	0.31	700	769.68	0.00	470.58	3.14	2.3	1.4	3.22	0.73	0.96	0.00	0	0.00	2.04		Tip V1
T534	10+160.15	28	0	0.24	0.00	700	769.68	372.40	0.00	2.48	1.8	1.4	2.52	0.79	0.911	0.49	0.97	2.71	2.07		H
T535	10+176.95	36	0	0.31	0.00	700	769.68	475.69	0.00	3.17	2.3	1.4	3.22	0.73	0.965	0.44	1.04	3.27	2.66		H
T536	10+192.29	13	0	0.11	0.00	700	769.68	174.26	0.00	1.16	0.9	1.4	1.26	0.88	0.801	0.60	0.68	1.55	0.88		H
T544	10+306.60	67	0	0.55	0.00	700	769.68	849.63	0.00	5.66	4.1	1.4	5.74	0.35	1.114	0.29	1.06	5.06	4.57		H
T545	10+312.02	22	0	0.19	0.00	700	769.68	293.72	0.00	1.96	1.4	1.4	1.96	0.83	0.869	0.53	0.86	2.21	1.56		H
T546	10+325.78	65	0	0.54	0.00	700	769.68	827.10	0.00	5.51	4	1.4	5.6	0.38	1.108	0.29	1.06	4.96	4.47		H
T584	10+925.08		-4.9	0.00	-0.04	700	769.68	0.00	-65.80		1.40	2.15	3.01	1.30				3.62	3.16	1.2	v2
T585	10+946.65	15	0	0.13	0.00	700	769.68	200.93	0.00	1.34	1	1.4	1.4	0.87	0.816	0.58	0.72	1.69	1.02		H
T587	10+960.85	18	0	0.16	0.00	700	769.68	240.81	0.00	1.61	1.2	1.4	1.68	0.86	0.839	0.56	0.81	1.97	1.3		H
T588	10+974.81	42	0	0.36	0.00	700	769.68	551.66	0.00	3.68	2.7	1.4	3.78	0.67	1.001	0.40	1.08	3.70	3.12		H
T594	11+057.80	12	0	0.10	0.00	700	769.68	160.91	0.00	1.07	0.9	1.4	1.26	0.88	0.794	0.61	0.69	1.56	0.88		H
T661	12+068.24	13	0	0.11	0.00	700	769.68	174.26	0.00	1.16	0.9	1.4	1.26	0.88	0.801	0.60	0.68	1.55	0.88		H
T663	12+084.06	10	0	0.09	0.00	700	769.68	134.16	0.00	0.89	0.9	1.4	1.26	0.89	0.778	0.62	0.72	1.59	0.9		H
T669	12+180.41	22		0.19	0.00	700	769.68	293.72	0.00	1.96	1.4	1.4	1.96	0.83	0.87	0.53	0.86	2.21			Most-prostorni
			-18.6	0.00	-0.16	700	769.68	0.00	-248.77		2.56	1.97	5.05	2.56				12.94	11.95	2.56	
T670	12+185.38	21		0.18	0.00	700	769.68	280.53	0.00	1.87	1.4	1.4	1.96	0.84	0.86	0.54	0.88	2.23	1.57		Most-prostorni
			18.6	0.00	0.16	700	769.68	0.00	248.77	1.66	1.2	1.4	1.68	0.85	0.84	0.00	0	0.00			
T671	12+196.71	21		0.18	0.00	700	769.68	280.53	0.00	1.87	1.4	1.4	1.96	0.84	0.86	0.54	0.88	2.23	1.57		Most-prostorni
			18.9	0.00	0.16	700	769.68	0.00	252.74	1.68	1.3	1.4	1.82	0.85	0.85	0.00	0	0.00			
T672	12+201.70	22		0.19	0.00	700	769.68	293.72	0.00	1.96	1.4	1.4	1.96	0.83	0.87	0.53	0.86	2.21			Most-prostorni
			-19	0.00	-0.17	700	769.68	0.00	-254.07		2.46	2.18	5.35	2.46				13.15	12.2	2.46	

TABELA ANKER BLOKOVA OD ODVOJKA N.TRAVNIK DO ODVOJKA VITEZ

Tjeme	Stacionaža	α -hor	α -ver	$\sin(\alpha\text{-hor}/2)$	$\sin(\alpha\text{-ver})/2$	Φ (mm)	N (kN)	$R = 2 \cdot N \cdot \sin(\alpha\text{-hor})/2$ (kN)	$R = 2 \cdot N \cdot \sin(\alpha\text{-ver})/2$ (kN)	potA= R/ σ (m2)	Usvojena dužina (A)	Usvojena širina (V)/visina (H) = (B)	Usvojena površina axb	a'	x	y	a''	Vbr	V m3	L	Tip bloka
T698	12+725.21	13		0.11	0.00	700	769.68	174.26	0.00	1.16	0.9	1.4	1.26	0.88	0.80	0.60	0.68	1.55			Most-prostorni
			-19.5	0.00	-0.17	700	769.68	0.00	-260.69		2.75	1.79	4.93	2.75				13.58	12.52	2.75	
T699	12+733.50	13		0.11	0.00	700	769.68	174.26	0.00	1.16	0.9	1.4	1.26	0.88	0.80	0.60	0.68	1.55			Most-prostorni
			19.5	0.00	0.17	700	769.68	0.00	260.69	1.74	1.3	1.4	1.82	0.85	0.85	0.00	0	0.00	1.28		
T700	12+747.33	13		0.11	0.00	700	769.68	174.26	0.00	1.16	0.9	1.4	1.26	0.88	0.80	0.60	0.68	1.55			Most-prostorni
			19.5	0.00	0.17	700	769.68	0.00	260.69	1.74	1.3	1.4	1.82	0.85	0.85	0.00	0	0.00	1.28		
T701	12+755.66	13		0.11	0.00	700	769.68	174.26	0.00	1.16	0.9	1.4	1.26	0.88	0.80	0.60	0.68	1.55			Most-prostorni
			-19.5	0.00	-0.17	700	769.68	0.00	-260.69		2.63	1.96	5.15	2.63				13.53	12.52	2.63	
T711	12+950.97	12	0	0.10	0.00	700	769.68	160.91	0.00	1.07	0.9	1.4	1.26	0.88	0.794	0.61	0.69	1.56	0.88		H
T723	13+116.73	12	0	0.10	0.00	700	769.68	160.91	0.00	1.07	0.9	1.4	1.26	0.88	0.794	0.61	0.69	1.56	0.88		H
T724	13+133.72	13	0	0.11	0.00	700	769.68	174.26	0.00	1.16	0.9	1.4	1.26	0.88	0.801	0.60	0.68	1.55	0.88		H
T740	13+391.36	18		0.16	0.00	700	769.68	240.81	0.00	1.61	1.2	1.4	1.68	0.86	0.84	0.56	0.81	1.97			Most-prostorni
			-19.1	0.00	-0.17	700	769.68	0.00	-255.39		2.71	1.81	4.91	2.71				13.30	12.26	2.71	
T741	13+397.27	18		0.16	0.00	700	769.68	240.81	0.00	1.61	1.2	1.4	1.68	0.86	0.84	0.56	0.81	1.97			Most-prostorni
			19	0.00	0.17	700	769.68	0.00	254.07	1.69	1.3	1.4	1.82	0.85	0.85	0.00	0	0.00	1.27		
T742	13+406.50	19		0.17	0.00	700	769.68	254.07	0.00	1.69	1.3	1.4	1.82	0.85	0.85	0.55	0.86	2.12			Most-prostorni
			19.1	0.00	0.17	700	769.68	0.00	255.39	1.70	1.3	1.4	1.82	0.85	0.85	0.00	0	0.00	1.28		
T743	13+412.13	19		0.17	0.00	700	769.68	254.07	0.00	1.69	1.3	1.4	1.82	0.85	0.85	0.55	0.86	2.12			Most-prostorni
			-19.4	0.00	-0.17	700	769.68	0.00	-259.37		2.62	1.96	5.14	2.62				13.46	12.45	2.62	
T751	13+553.47	16	0	0.14	0.00	700	769.68	214.24	0.00	1.43	1.2	1.2	1.44	0.87	0.824	0.58	0.84	1.71	1.08		H
T781	14+227.44	27		0.23	0.00	700	769.68	359.36	0.00	2.40	1.8	1.4	2.52	0.80	0.90	0.50	0.99	2.73			Most-prostorni
			-17.9	0.00	-0.16	700	769.68	0.00	-239.48		2.58	1.87	4.83	2.58				12.49	11.5	2.58	
T782	14+235.43	27		0.23	0.00	700	769.68	359.36	0.00	2.40	1.8	1.4	2.52	0.80	0.90	0.50	0.99	2.73	2.08		Most-prostorni
			17.8	0.00	0.15	700	769.68	0.00	238.15	1.59	1.2	1.4	1.68	0.86	0.84	0.00	0	0.00			
T783	14+250.45	26		0.22	0.00	700	769.68	346.28	0.00	2.31	1.7	1.4	2.38	0.81	0.90	0.50	0.96	2.61	1.95		Most-prostorni
			18.1	0.00	0.16	700	769.68	0.00	242.14	1.61	1.2	1.4	1.68	0.86	0.84	0.00	0	0.00			
T784	14+258.85	26		0.22	0.00	700	769.68	346.28	0.00	2.31	2	1.2	2.4	0.81	0.90	0.50	1.13	2.63			Most-prostorni
			-18.4	0.00	-0.16	700	769.68	0.00	-246.11		2.66	1.82	4.83	2.66				12.84	11.82	2.66	
T802	14+581.83	10	0	0.09	0.00	700	769.68	134.16	0.00	0.89	0.9	1.2	1.08	0.89	0.778	0.62	0.72	1.36	0.72		H
																			298.26		

V1-vertikalni lom sa rezultantom prema dole

V2-vertikalni lom sa rezultantom prema gore

H - Horizontalni lom

TABELA ANKER BLOKOVA OD ODVOJKA VITEZ DO ODVOJKA BUSOVAČA

Tjeme	Stacionaža	α -hor	α -ver	$\sin(\alpha\text{-hor}/2)$	$\sin(\alpha\text{-ver})/2$	Φ (mm)	N (kN)	$R = 2 * N * \sin(\alpha\text{-hor})/2$ (kN)	$R = 2 * N * \sin(\alpha\text{-ver})/2$ (kN)	$\rho \sigma A = R/\sigma$ (m ²)	Usvojena dužina (A)	Usvojena širina (V)/visina (H) = (B)	Usvojena površina axb	a'	x	y	a''	Vbr	V m ³	L	Tip bloka
T816	14+801.22	11	0	0.10	0.00	700	769.68	147.54	0.00	0.98	0.9	1.4	1.26	0.88	0.786	0.61	0.71	1.58	0.89		H
T826	15+074.99	27	0	0.23	0.00	700	769.68	359.36	0.00	2.40	1.8	1.4	2.52	0.80	0.904	0.50	0.99	2.73	2.08		H
T827	15+085.19	10	0	0.09	0.00	700	769.68	134.16	0.00	0.89	0.9	1.4	1.26	0.89	0.778	0.62	0.72	1.59	0.9		H
T828	15+094.29	18	0	0.16	0.00	700	769.68	240.81	0.00	1.61	1.2	1.4	1.68	0.86	0.839	0.56	0.81	1.97	1.3		H
T830	15+136.55	13	0	0.11	0.00	700	769.68	174.26	0.00	1.16	0.9	1.4	1.26	0.88	0.801	0.60	0.68	1.55	0.88		H
T832	15+164.42	13	0	0.11	0.00	700	769.68	174.26	0.00	1.16	0.9	1.4	1.26	0.88	0.801	0.60	0.68	1.55	0.88		H
T834	15+207.13	13	0	0.11	0.00	700	769.68	174.26	0.00	1.16	0.9	1.4	1.26	0.88	0.801	0.60	0.68	1.55	0.88		H
T843	15+381.07	13	0	0.11	0.00	700	769.68	174.26	0.00	1.16	0.9	1.4	1.26	0.88	0.801	0.60	0.68	1.55	0.88		H
T844	15+386.10	17	0	0.15	0.00	700	769.68	227.53	0.00	1.52	1.1	1.4	1.54	0.86	0.832	0.57	0.76	1.82	1.16		H
T846	15+443.43	90	0	0.71	0.00	700	769.68	1088.49	0.00	7.26	5.2	1.4	7.28	0.00	1.150	0.25	1.14	6.21	5.77		H
T847	15+455.21	89	0	0.70	0.00	700	769.68	1078.95	0.00	7.19	5.2	1.4	7.28	0.02	1.150	0.25	1.14	6.21	5.77		H
T848	15+491.90	40	0	0.34	0.00	700	769.68	526.49	0.00	3.51	2.6	1.4	3.64	0.69	0.989	0.41	1.08	3.61	3.01		H
T849	15+524.23	39	0	0.33	0.00	700	769.68	513.85	0.00	3.43	2.5	1.4	3.5	0.70	0.983	0.42	1.06	3.49	2.89		H
T850	15+541.09	30	0	0.26	0.00	700	769.68	398.42	0.00	2.66	1.9	1.4	2.66	0.78	0.925	0.48	0.98	2.82	2.19		H
T851	15+557.93	41	0	0.35	0.00	700	769.68	539.10	0.00	3.59	2.6	1.4	3.64	0.68	0.995	0.40	1.06	3.59	3		H
T855	15+669.29		-14	0.00	-0.12	700	769.68	0.00	-187.60	0.00	2.28	1.90	4.33	2.28				9.89	9.01	2.28	V2
T856	15+675.95		14	0.00	0.12	700	769.68	0.00	187.60	1.25	0.9	1.4	1.26	0.87	0.81	0.00	0	0.00	1.00		v1
T858	15+686.33		20.2	0.00	0.18	700	769.68	0.00	269.95	1.80	1.3	1.4	1.82	0.84	0.86	0.00	0	0.00	1.28		v1
T859	15+691.25		-20.3	0.00	-0.18	700	769.68	0.00	-271.27	0.00	2.76	1.85	5.11	2.76				14.09	13.03	2.76	v2
T889	16+511.29	10	0	0.09	0.00	700	769.68	134.16	0.00	0.89	0.9	1.4	1.26	0.89	0.778	0.62	0.72	1.59	0.9		H
T901	17+203.82		14.6	0.00	0.13	700	769.68	0.00	195.60	1.30	1	1.4	1.4	0.87	0.81	0.00	0	0.00	1.07		v1
T902	17+239.77		-15.4	0.00	-0.13	700	769.68	0.00	-206.25	0.00	2.39	1.90	4.54	2.39				10.83	9.91	2.39	v2
T905	17+441.61	14	0	0.12	0.00	700	769.68	187.60	0.00	1.25	0.9	1.4	1.26	0.87	0.809	0.59	0.66	1.53	0.87		H
T910	17+850.40		-5	0.00	-0.04	700	769.68	0.00	-67.15	0.00	2.12	0.90	1.91	2.12				4.05	3.23	2.12	v1
T911	17+872.18		-27.1	0.00	-0.23	700	769.68	0.00	-360.66	0.00	3.12	1.90	5.93	3.12				18.52	17.32	3.12	v2
T912	17+886.09		34.8	0.00	0.30	700	769.68	0.00	460.33	3.07	2.2	1.4	3.08	0.74	0.96	0.00	0	0.00	1.97		v1
T914	17+918.95		11.1	0.00	0.10	700	769.68	0.00	148.88	0.99	0.9	1.4	1.26	0.88	0.79	0.00	0	0.00	0.98		v2
T915	17+922.83		10.6	0.00	0.09	700	769.68	0.00	142.19	0.95	0.9	1.4	1.26	0.88	0.78	0.00	0	0.00	0.98		v3
T916	17+935.67		-21.7	0.00	-0.19	700	769.68	0.00	-289.77	0.00	2.81	1.90	5.34	2.81				14.99	13.91	2.81	v2
T917	17+954.49		-26.9	0.00	-0.23	700	769.68	0.00	-358.05	0.00	3.11	1.90	5.91	3.11				18.39	17.19	3.11	v2
T921	17+971.99		25	0.00	0.22	700	769.68	0.00	333.18	2.22	1.6	1.4	2.24	0.82	0.89	0.00	0	0.00	1.51		v1
T922	17+984.64		53.7	0.00	0.45	700	769.68	0.00	695.26	4.64	3.4	1.4	4.76	0.53	1.06	0.00	0	0.00	2.93		v1
T923	17+988.74		-23	0.00	-0.20	700	769.68	0.00	-306.90	0.00	2.89	1.90	5.49	2.89				15.85	14.74	2.89	v2
T924	17+994.02		-23	0.00	-0.20	700	769.68	0.00	-306.90	0.00	2.89	1.90	5.49	2.89				15.85	14.74	2.89	v2
T925	18+004.54		-6.3	0.00	-0.05	700	769.68	0.00	-84.59	0.00	1.57	1.90	2.98	1.57				4.67	4.07	1.57	v2
T926	18+079.56		-4.4	0.00	-0.04	700	769.68	0.00	-59.09	0.00	1.40	1.90	2.66	1.32				3.32	2.84	1.25	v3
T927	18+088.15		-28.6	0.00	-0.25	700	769.68	0.00	-380.22	0.00	3.20	1.90	6.09	3.20				19.49	18.26	3.2	v2
T929	18+092.82		-18.6	0.00	-0.16	700	769.68	0.00	-248.77	0.00	2.61	1.90	4.96	2.61				12.95	11.95	2.61	v2
T930	18+097.37		51.5	0.00	0.43	700	769.68	0.00	668.77	4.46	3.2	1.4	4.48	0.56	1.05	0.00	0	0.00	2.77		v1

TABELA ANKER BLOKOVA OD ODVOJKA VITEZ DO ODVOJKA BUSOVAČA

Tjeme	Stacionaža	α -hor	α -ver	$\sin(\alpha\text{-hor}/2)$	$\sin(\alpha\text{-ver})/2$	Φ (mm)	N (kN)	$R = 2 * N * \sin(\alpha\text{-hor})/2$ (kN)	$R = 2 * N * \sin(\alpha\text{-ver})/2$ (kN)	$\rho \sigma A = R/\sigma$ (m ²)	Usvojena dužina (A)	Usvojena širina (V)/visina (H) = (B)	Usvojena površina axb	a'	x	y	a''	Vbr	V m ³	L	Tip bloka
T931	18+108.41		41.9	0.00	0.36	700	769.68	0.00	550.40	3.67	2.7	1.4	3.78	0.67	1.00	0.00	0	0.00	2.36		v1
T932	18+116.93		-36.2	0.00	-0.31	700	769.68	0.00	-478.24		3.58	1.90	6.80	3.58				24.34	22.96	3.58	v2
T933	18+129.61		-5.9	0.00	-0.05	700	769.68	0.00	-79.22		1.52	1.90	2.89	1.52				4.40	3.81	1.52	v2
T939	18+423.13	13		0.11	0.00	700	769.68	174.26	0.00	1.16	0.9	1.4	1.26	0.88	0.80	0.60	0.68	1.55			Prostorni
			-7.9	0.00	-0.07	700	769.68	0.00	-106.04		1.74	1.90	3.31	1.74				5.76	5.09	1.74	
T949	18+677.17		-34.3	0.00	-0.29	700	769.68	0.00	-453.92		3.49	1.90	6.63	3.49				23.13	21.79	3.49	v2
T950	18+680.61		35.4	0.00	0.30	700	769.68	0.00	468.02	3.12	2.3	1.4	3.22	0.73	0.96	0.00	0	0.00	2.04		v1
T952	18+719.58		32.20	0.00	0.28	700	769.68	0.00	426.89	2.85	2.1	1.4	2.94	0.76	0.94	0.00	0	0.00	1.88		v1
T953	18+724.24	3	-31.80	0.03	-0.27	700	769.68	40.30	-421.72		3.17	2.14	6.78	3.17				21.47	20.25	3.17	v2
T954	18+769.68	11	0.00	0.10	0.00	700	769.68	147.54	0.00	0.98	0.9	1.4	1.26	0.88	0.786	0.61	0.71	1.58			Prostorni
		0	5.20	0.00	0.05	700	769.68	0.00	69.83	0.47	0.9	1.4	1.26	0.90	0.74	0.00	0	0.00	0.93		
T955/P751	18+807.96	11	0.00	0.10	0.00	700	769.68	147.54	0.00	0.98	0.9	1.4	1.26	0.88	0.786	0.61	0.71	1.58			Prostorni
		0	-5.60	0.00	-0.05	700	769.68	0.00	-75.20		1.48	1.90	2.82	1.48				4.18	3.61	1.48	
T967	19+159.51	9		0.08	0.00	700	769.68	120.78	0.00	0.81	0.9	1.4	1.26	0.89	0.770	0.63	0.74	1.61	0.91		H
T968	19+169.82	11	5.00	0.10	0.04	700	769.68	147.54	67.15	0.98	0.9	1.4	1.26	0.88	0.786	0.61	0.71	1.58	0.89		H
T969/P766	19+183.21	6	-4.40	0.05	-0.04	700	769.68	80.56	-59.09		1.40	2.14	3.00	1.23				3.26	2.84	1.09	V2
T978/P773	19+357.79																				
T1081	20+414.27		-21.50	0.00	-0.19	600	565.48	0.00	-210.95		2.40	1.87	4.50	2.40				10.81	10.13	2.4	V2
T1082	20+423.40		21.20	0.00	0.18	600	565.48	0.00	208.04	1.39	1.2	1.2	1.44	0.84	0.76	0.00	0	0.00	0.93		V1
T1083	20+432.75		18.10	0.00	0.16	600	565.48	0.00	177.90	1.19	1	1.2	1.2	0.86	0.74	0.00	0	0.00	0.82		V1
T1084	20+444.08		-17.80	0.00	-0.15	600	565.48	0.00	-174.97		2.23	1.82	4.05	2.23				9.03	8.4	2.23	V2
T1145	21+395.19	20		0.17	0.00	600	565.48	196.39	0.00	1.31	1.1	1.2	1.32	0.85	0.754	0.45	0.66	1.27	0.82		H
T1146	21+401.98	20		0.17	0.00	600	565.48	196.39	0.00	1.31	1.1	1.2	1.32	0.85	0.754	0.45	0.66	1.27	0.82		H
T1147	21+409.13	19		0.17	0.00	600	565.48	186.66	0.00	1.24	1.1	1.2	1.32	0.85	0.747	0.45	0.67	1.27	0.82		H
T1148	21+416.38	18		0.16	0.00	600	565.48	176.92	0.00	1.18	1	1.2	1.2	0.86	0.739	0.46	0.63	1.17	0.72		H
T1174	21+853.49	15		0.13	0.00	600	565.48	147.62	0.00	0.98	0.9	1.2	1.08	0.87	0.716	0.48	0.61	1.09	0.62		H
T1177	21+922.34	10		0.09	0.00	600	565.48	98.57	0.00	0.66	0.9	1.2	1.08	0.89	0.678	0.52	0.7	1.15	0.65		H
T1178	21+937.97	15		0.13	0.00	600	565.48	147.62	0.00	0.98	0.9	1.2	1.08	0.87	0.716	0.48	0.61	1.09	0.62		H
T1191/P888	22+216.53		-6.10	0.00	-0.05	600	565.48	0.00	-60.18		1.31	1.90	2.49	1.31				3.26	2.89	1.31	V2
T1197	22+305.66	14		0.12	0.00	600	565.48	137.83	0.00	0.92	0.9	1.2	1.08	0.87	0.709	0.49	0.63	1.10			Prostorni
			-20.50	0.00	-0.18	600	565.48	0.00	-201.25		2.05	2.43	4.99	2.05				10.24	9.66	2.05	
T1198	22+310.86		21.10	0.00	0.18	600	565.48	0.00	207.07	1.38	1.2	1.2	1.44	0.84	0.76	0.00	0	0.00	0.93		V1
T1199	22+333.40	25		0.22	0.00	600	565.48	244.78	0.00	1.63	1.4	1.2	1.68	0.82	0.790	0.41	0.73	1.53	1.09		Prostorni
			19.00	0.00	0.17	600	565.48	0.00	186.66	1.24	1.1	1.2	1.32	0.85	0.75	0.00	0	0.00			
T1200	22+340.21	22		0.19	0.00	600	565.48	215.80	0.00	1.44	1.2	1.2	1.44	0.83	0.769	0.43	0.68	1.35			Prostorni
			-19.50	0.00	-0.17	600	565.48	0.00	-191.53		2.23	1.97	4.40	2.23				9.83	9.2	2.23	

Ukupno:

337.43

TABELA ANKER BLOKOVA OD ODVOJKA BUSOVAČA DO REZERVOARA PUTOVIČI

Tjeme	Stacionaža	α -hor	α -ver	$\sin(\alpha\text{-hor}/2)$	$\sin(\alpha\text{-ver})/2$	Φ (mm)	N (kN)	$R = 2 * N * \sin(\alpha\text{-hor})/2$ (kN)	$R = 2 * N * \sin(\alpha\text{-ver})/2$ (kN)	$\rho\alpha A = R/\sigma$ (m2)	Usvojena dužina (A)	Usvojena širina (V)/visina (H) = (B)	Usvojena površina axb	a'	x	y	a''	Vbr	V m3	L	Tip bloka
T1202	22+360.23	9		0.08	0.00	600	565.48	88.73	0.00	0.59	0.9	1.2	1.08	0.89	0.670	0.53	0.72	1.17	0.66		H
T1204	22+400.96	14		0.12	0.00	600	565.48	137.83	0.00	0.92	0.9	1.2	1.08	0.87	0.709	0.49	0.63	1.10	0.63		H
T1206	22+451.61	11		0.10	0.00	600	565.48	108.40	0.00	0.72	0.9	1.2	1.08	0.88	0.686	0.51	0.68	1.14	0.65		H
T1207	22+483.42	18	2.60	0.16	0.02	600	565.48	176.92	25.66	1.18	1	1.2	1.2	0.86	0.739	0.46	0.63	1.17	0.72		H
T1208	22+509.63	4	-4.00	0.03	-0.03	600	565.48	39.47	-39.47		1.20	1.90	2.28	1.07				2.17	1.9	0.95	V2
T1220/P905	22+655.58		-4.00	0.00	-0.03	600	565.48	0.00	-39.47		1.20	1.99	2.39	1.04				2.16	1.9	0.9	V2
T1221	22+664.24	10	3.90	0.09	0.03	600	565.48	98.57	38.48	0.66	0.9	1.2	1.08	0.89	0.678	0.52	0.7	1.15	0.65		H
T1222	22+674.40	22	4.70	0.19	0.04	600	565.48	215.80	46.37	1.44	1.2	1.2	1.44	0.83	0.769	0.43	0.68	1.35	0.91		H
T1223	22+681.61	22		0.19	0.00	600	565.48	215.80	0.00	1.44	1.2	1.2	1.44	0.83	0.769	0.43	0.68	1.35			Prostorni
			-4.70	0.00	-0.04	600	565.48	0.00	-46.37		1.20	1.99	2.39	1.13				2.53	2.23	1.06	
T1235	22+902.23		-16.00	0.00	-0.14	600	565.48	0.00	-157.40		2.04	1.95	3.98	2.04				8.14	7.56	2.04	V2
T1236	22+907.58	2	16.50	0.02	0.14	600	565.48	19.74	162.28	1.08	1	1.2	1.2	0.86	0.73	0.00	0	0.00	0.81		V1
T1237	22+921.85		16.10	0.00	0.14	600	565.48	0.00	158.38	1.06	0.9	1.2	1.08	0.86	0.72	0.00	0	0.00	0.77		V1
T1238	22+926.41		-16.10	0.00	-0.14	600	565.48	0.00	-158.38		1.93	2.18	4.22	1.93				8.16	7.61	1.93	V2
T1240	22+953.31	15		0.13	0.00	600	565.48	147.62	0.00	0.98	0.9	1.2	1.08	0.87	0.716	0.48	0.61	1.09	0.62		H
T1273	23+456.15	9		0.08	0.00	600	565.48	88.73	0.00	0.59	0.9	1.2	1.08	0.89	0.670	0.53	0.72	1.17	0.66		H
T1290	23+756.20	9		0.08	0.00	600	565.48	88.73	0.00	0.59	0.9	1.2	1.08	0.89	0.670	0.53	0.72	1.17	0.66		H
T1309	24+085.48	12		0.10	0.00	600	565.48	118.22	0.00	0.79	0.9	1.2	1.08	0.88	0.694	0.51	0.66	1.12	0.64		H
T1310	24+098.42	29		0.25	0.00	500	490.63	245.69	0.00	1.64	1.4	1.2	1.68	0.79	0.718	0.28	0.55	1.17			Prostorni
			-10.10	0.00	-0.09	500	490.63	0.00	-86.38		1.53	1.90	2.91	1.53				4.45	4.15	1.53	
T1311	24+116.39	33		0.28	0.00	500	490.63	278.69	0.00	1.86	1.6	1.2	1.92	0.75	0.745	0.25	0.55	1.29	1.02		Prostorni
			10.10	0.00	0.09	500	490.63	0.00	86.38	0.58	0.9	1.2	1.08	0.89	0.58	0.00	0	0.00			
T1313	24+157.07	10		0.09	0.00	500	490.63	85.52	0.00	0.57	0.9	1.2	1.08	0.89	0.578	0.42	0.66	0.94	0.57		H
T1314	24+167.77		-5.10	0.00	-0.04	500	490.63	0.00	-43.66		1.40	2.05	2.87	1.05				2.25	2.1	0.79	V2
T1315	24+174.58	21		0.18	0.00	500	490.63	178.82	0.00	1.19	1	1.2	1.2	0.84	0.661	0.34	0.52	0.91	0.6		H
T1321	24+318.42	10		0.09	0.00	500	490.63	85.52	0.00	0.57	0.9	1.2	1.08	0.89	0.578	0.42	0.66	0.94	0.57		H
T1324	24+346.97	11		0.10	0.00	500	490.63	94.05	0.00	0.63	0.9	1.2	1.08	0.88	0.586	0.41	0.64	0.92	0.56		H
T1327	24+383.28	10		0.09	0.00	500	490.63	85.52	0.00	0.57	0.9	1.2	1.08	0.89	0.578	0.42	0.66	0.94	0.57		H
T1333	24+462.16	11		0.10	0.00	500	490.63	94.05	0.00	0.63	0.9	1.2	1.08	0.88	0.586	0.41	0.64	0.92	0.56		H
T1334	24+480.39	13		0.11	0.00	500	490.63	111.08	0.00	0.74	0.9	1.2	1.08	0.88	0.601	0.40	0.6	0.90	0.55		H
T1338	24+554.48	10		0.09	0.00	500	490.63	85.52	0.00	0.57	0.9	1.2	1.08	0.89	0.578	0.42	0.66	0.94	0.57		H
T1349	24+716.27	23		0.20	0.00	500	490.63	195.63	0.00	1.30	1.1	1.2	1.32	0.83	0.676	0.32	0.53	0.98			Prostorni
			-16.20	0.00	-0.14	500	490.63	0.00	-138.26		1.82	2.12	3.85	1.82				7.00	6.64	1.82	
T1350	24+721.02	20		0.17	0.00	500	490.63	170.39	0.00	1.14	1	1.2	1.2	0.85	0.654	0.35	0.53	0.92	0.6		Prostorni
			16.10	0.00	0.14	500	490.63	0.00	137.41	0.92	0.9	1.2	1.08	0.86	0.62	0.00	0	0.00			
T1351	24+730.70	21		0.18	0.00	500	490.63	178.82	0.00	1.19	1	1.2	1.2	0.84	0.661	0.34	0.52	0.91	0.6		Prostorni
			15.80	0.00	0.14	500	490.63	0.00	134.87	0.90	0.9	1.2	1.08	0.87	0.62	0.00	0	0.00			

TABELA ANKER BLOKOVA OD ODVOJKA BUSOVAČA DO REZERVOARA PUTOVIČI

<i>Tjeme</i>	Stacionaža	α -hor	α -ver	sin (α -hor/2)	sin (α -ver)/2	Φ (mm)	N (kN)	$R = 2 * N * \sin (\alpha\text{-hor})/2$ (kN)	$R = 2 * N * \sin (\alpha\text{-ver})/2$ (kN)	potA= R/ σ (m2)	Usvojena dužina (A)	Usvojena širina (V)/visina (H) = (B)	Usvojena površina axb	a'	x	y	a''	Vbr	V m3	L	Tip bloka
T1352	24+735.48	20		0.17	0.00	500	490.63	170.39	0.00	1.14	1	1.2	1.2	0.85	0.654	0.35	0.53	0.92			Prostorni
			-15.70	0.00	-0.14	500	490.63	0.00	-134.02		1.88	1.93	3.63	1.88				6.81	6.44	1.88	
T1383/P1001	25+062.75	11		0.10	0.00	500	490.63	94.05	0.00	0.63	0.9	1.2	1.08	0.88	0.586	0.41	0.64	0.92	0.56		H
T1420/P1027	25+717.65	13		0.11	0.00	500	490.63	111.08	0.00	0.74	0.9	1.2	1.08	0.88	0.601	0.40	0.6	0.90			Prostorni
			-11.9	0.00	-0.10	500	490.63	0.00	-101.72		1.57	2.12	3.32	1.57				5.20	4.89	1.57	
T1421	25+737.05		11.2	0.00	0.10	500	490.63	0.00	95.75	0.64	0.9	1.2	1.08	0.88	0.59	0.00	0	0.00	0.63		V1
T1426	25+939.92	11		0.10	0.00	500	490.63	94.05	0.00	0.63	0.9	1.2	1.08	0.88	0.586	0.41	0.64	0.92	0.56		H
T1427	25+976.58		18.6	0.00	0.16	500	490.63	0.00	158.58	1.06	0.9	1.2	1.08	0.85	0.64	0.00	0	0.00	0.68		V1
T1428/P1038	25+987.09		-19.1	0.00	-0.17	500	490.63	0.00	-162.80		2.00	2.05	4.10	2.00				8.21	7.82	2	V2
T1429	25+992.67	38		0.33	0.00	500	490.63	319.47	0.00	2.13	1.8	1.2	2.16	0.71	0.777	0.22	0.52	1.39	1.14		H
T1435	26+091.86	9		0.08	0.00	500	490.63	76.99	0.00	0.51	0.9	1.2	1.08	0.89	0.570	0.43	0.68	0.95	0.57		H
T1444/P1047	26+211.96	11		0.10	0.00	500	490.63	94.05	0.00	0.63	0.9	1.2	1.08	0.88	0.586	0.41	0.64	0.92	0.56		H
T1448/P1049	26+262.13	12		0.10	0.00	500	490.63	102.57	0.00	0.68	0.9	1.2	1.08	0.88	0.594	0.41	0.62	0.91	0.56		H
T1452	26+327.75	13		0.11	0.00	500	490.63	111.08	0.00	0.74	0.9	1.2	1.08	0.88	0.601	0.40	0.6	0.90	0.55		H
T1453	26+353.25	12		0.10	0.00	500	490.63	102.57	0.00	0.68	0.9	1.2	1.08	0.88	0.594	0.41	0.62	0.91	0.56		H
T1462/P1062	26+587.58	6	-2.9	0.05	-0.03	500	490.63	51.36	-24.83		1.40	2.05	2.87	0.79				1.29	1.2	0.45	V2
T1474	26+747.37	11		0.10	0.00	500	490.63	94.05	0.00	0.63	0.9	1.2	1.08	0.88	0.586	0.41	0.64	0.92	0.56		H
T1476	26+771.32	9		0.08	0.00	500	490.63	76.99	0.00	0.51	0.9	1.2	1.08	0.89	0.570	0.43	0.68	0.95	0.57		H
T1488	26+924.75	13		0.11	0.00	500	490.63	111.08	0.00	0.74	0.9	1.2	1.08	0.88	0.601	0.40	0.6	0.90	0.55		H
T1490	26+944.54	11		0.10	0.00	500	490.63	94.05	0.00	0.63	0.9	1.2	1.08	0.88	0.586	0.41	0.64	0.92	0.56		H
T1497/P1081	27+056.07	21		0.18	0.00	500	490.63	178.82	0.00	1.19	1	1.2	1.2	0.84	0.661	0.34	0.52	0.91	0.6		H
T1505/P1085	27+156.23		-20.2	0.00	-0.18	500	490.63	0.00	-172.08		2.06	2.05	4.21	2.06				8.66	8.26	2.06	V2
T1518	27+315.75	11		0.10	0.00	500	490.63	94.05	0.00	0.63	0.9	1.2	1.08	0.88	0.586	0.41	0.64	0.92	0.56		H
T1519	27+317.85	20		0.17	0.00	500	490.63	170.39	0.00	1.14	1	1.2	1.2	0.85	0.654	0.35	0.53	0.92	0.6		H
T1520	27+324.46		18.3	0.00	0.16	500	490.63	0.00	156.04	1.04	0.9	1.2	1.08	0.85	0.64	0.00	0	0.00	0.68		V1
T1524/P1097	27+460.81		-10.5	0.00	-0.09	500	490.63	0.00	-89.79		1.50	2.05	3.07	1.50				4.60	4.31	1.5	V2
T1526	27+512.54	27		0.23	0.00	500	490.63	229.07	0.00	1.53	1.3	1.2	1.56	0.80	0.704	0.30	0.55	1.11	0.82		H
T1527	27+525.74	15		0.13	0.00	500	490.63	128.08	0.00	0.85	0.9	1.2	1.08	0.87	0.616	0.38	0.56	0.88	0.54		H
T1528	27+537.70	20		0.17	0.00	500	490.63	170.39	0.00	1.14	1	1.2	1.2	0.85	0.654	0.35	0.53	0.92	0.6		H
T1530 (T1507)	27+600.91		-89	0.00	-0.70	500	490.63	0.00	-687.77		4.06	2.05	8.33	4.06				33.82	33.02	4.06	V2
	27+600.91		90	0.00	0.71	500	490.63	0.00	693.86	4.63	3.9	1.2	4.68	0.00	0.95	0.00	0	0.00	2.22		V1
T1531(T1508)	27+660.02		90	0.00	0.71	500	490.63	0.00	693.86	4.63	3.9	1.2	4.68	0.00	0.95	0.00	0	0.00	2.22		V1
	27+660.02		-90	0.00	-0.71	500	490.63	0.00	-693.86		4.08	2.05	8.36	4.08				34.11	33.31	4.08	V2
T1532	27+675.39	66		0.54	0.00	500	490.63	534.43	0.00	3.56	3	1.2	3.6	0.37	0.911	0.09	0.3	1.98	1.79		H
T1533	27+692.12	10		0.09	0.00	500	490.63	85.52	0.00	0.57	0.9	1.2	1.08	0.89	0.578	0.42	0.66	0.94	0.57		H
T1534	27+707.81	17		0.15	0.00	500	490.63	145.04	0.00	0.97	0.9	1.2	1.08	0.86	0.632	0.37	0.53	0.86	0.53		H
T1535	27+717.18		12	0.00	0.10	500	490.63	0.00	102.57	0.68	0.9	1.2	1.08	0.88	0.59	0.00	0	0.00	0.63		V1

TABELA ANKER BLOKOVA OD ODVOJKA BUSOVAČA DO REZERVOARA PUTOVIĆI

Tjeme	Stacionaža	α -hor	α -ver	$\sin(\alpha\text{-hor}/2)$	$\sin(\alpha\text{-ver})/2$	Φ (mm)	N (kN)	$R = 2 * N * \sin(\alpha\text{-hor})/2$ (kN)	$R = 2 * N * \sin(\alpha\text{-ver})/2$ (kN)	$\rho \sigma A = R/\sigma$ (m2)	Usvojena dužina (A)	Usvojena širina (V)/visina (H) = (B)	Usvojena površina axb	a'	x	y	a''	Vbr	V m3	L	Tip bloka
T1537	27+741.75		-21	0.00	-0.18	500	490.63	0.00	-178.82		2.10	2.05	4.30	2.10				9.00	8.59	2.1	V2
T1538	27+745.65	10		0.09	0.00	500	490.63	85.52	0.00	0.57	0.9	1.2	1.08	0.89	0.578	0.42	0.66	0.94	0.57		H
T1539	27+776.96	9		0.08	0.00	500	490.63	76.99	0.00	0.51	0.9	1.2	1.08	0.89	0.570	0.43	0.68	0.95	0.57		H
T1540	27+817.76		-5	0.00	-0.04	500	490.63	0.00	-42.80		1.40	2.05	2.87	1.04				2.21	2.06	0.77	V2
T1544	27+917.84	12	-6	0.10	-0.05	500	490.63	102.57	-51.36		1.40	2.05	2.87	1.14				2.65	2.47	0.92	V2
T1550/P1123	28+083.89		-9.5	0.00	-0.08	500	490.63	0.00	-81.26		1.43	2.05	2.93	1.43				4.19	3.91	1.43	V2
T1551	28+091.86	18		0.16	0.00	500	490.63	153.50	0.00	1.02	0.9	1.2	1.08	0.86	0.639	0.36	0.51	0.85	0.53		H
T1554	28+246.34	12		0.10	0.00	500	490.63	102.57	0.00	0.68	0.9	1.2	1.08	0.88	0.594	0.41	0.62	0.91	0.56		H
T1555	28+267.63		-13.6	0.00	-0.12	500	490.63	0.00	-116.19		1.70	2.05	3.48	1.70				5.91	5.58	1.7	V2
T1557	28+287.17		13.3	0.00	0.12	500	490.63	0.00	113.63	0.76	0.9	1.2	1.08	0.88	0.60	0.00	0	0.00	0.64		V1
T1559/P1135	28+386.21		-4.2	0.00	-0.04	500	490.63	0.00	-35.96		1.40	2.05	2.87	0.95				1.86	1.73	0.65	V2
T1560	28+397.26	18		0.16	0.00	500	490.63	153.50	0.00	1.02	0.9	1.2	1.08	0.86	0.639	0.36	0.51	0.85	0.53		H
T1563/P1139	28+487.35		-3.6	0.00	-0.03	500	490.63	0.00	-30.82		1.40	2.05	2.87	0.88				1.59	1.48	0.55	V2
T1567	28+567.92		-7.3	0.00	-0.06	500	490.63	0.00	-62.47		1.40	2.05	2.87	1.25				3.22	3	1.12	V2
T1570	28+631.96		-8.3	0.00	-0.07	500	490.63	0.00	-71.01		1.40	2.05	2.87	1.34				3.66	3.41	1.28	V2
T1573	28+681.39		-90	0.00	-0.71	500	490.63	0.00	-693.86		3.34	3.05	10.18	3.34				33.97	33.31	3.34	V2
	28+681.39		90	0.00	0.71	500	490.63	0.00	693.86	4.63	3.9	1.2	4.68	0.00	0.95	0.00	0	0.00	2.22		V1
T1574	28+719.65	87		0.69	0.00	500	490.63	675.45	0.00	4.50	3.8	1.2	4.56	0.05	0.949	0.05	0.21	2.41	2.23		H
T1597	29+687.54	87		0.69	0.00	500	490.63	675.45	0.00	4.50	3.8	1.2	4.56	0.05	0.949	0.05	0.21	2.41	2.23		H
T1598	29+722.18		89	0.00	0.70	500	490.63	0.00	687.77	4.59	3.9	1.2	4.68	0.02	0.95	0.00	0	0.00	2.23		V1
	29+722.18		-88	0.00	-0.69	500	490.63	0.00	-681.64		3.31	3.05	10.09	3.31				33.37	32.72	3.31	V2
T1619/P1215	30377.22	9		0.08	0.00	500	490.63	76.99	0.00	0.51	0.9	1.2	1.08	0.89	0.570	0.43	0.68	0.95	0.57		H
T1631	30+860.46	12		0.10	0.00	500	490.63	102.57	0.00	0.68	0.9	1.2	1.08	0.88	0.594	0.41	0.62	0.91	0.56		H
T1632	30+888.91	11		0.10	0.00	500	490.63	94.05	0.00	0.63	0.9	1.2	1.08	0.88	0.586	0.41	0.64	0.92	0.56		H
T1633/P1236	30+902.77	51		0.43	0.00	500	490.63	422.44	0.00	2.82	2.4	1.2	2.88	0.57	0.850	0.15	0.43	1.70	1.48		H
T1634	30+919.23	40		0.34	0.00	500	490.63	335.61	0.00	2.24	1.9	1.2	2.28	0.69	0.789	0.21	0.51	1.45	1.2		H
T1642	31+213.47		-29	0.00	-0.25	500	490.63	0.00	-245.69		2.45	2.05	5.02	2.45				12.28	11.8	2.45	V2
T1643	31+215.81		28	0.00	0.24	500	490.63	0.00	237.39	1.58	1.4	1.2	1.68	0.79	0.71	0.00	0	0.00	0.94		V1
T1644	31+219.88	89		0.70	0.00	500	490.63	687.77	0.00	4.59	3.9	1.2	4.68	0.02	0.950	0.05	0.21	2.47	2.29		H
T1645	31+275.79		-89	0.00	-0.70	500	490.63	0.00	-687.77		3.32	3.05	10.13	3.32				33.67	33.02	3.32	V1
	31+275.79		90	0.00	0.71	500	490.63	0.00	693.86	4.63	3.9	1.2	4.68	0.00	0.95	0.00	0	0.00	2.22		V2
T1646	31+418.95		90	0.00	0.71	500	490.63	0.00	693.86	4.63	3.9	1.2	4.68	0.00	0.95	0.00	0	0.00	2.22		V2
	31+418.95		-83	0.00	-0.66	500	490.63	0.00	-650.20		3.23	3.05	9.86	3.23				31.84	31.21	3.23	V1
T1648	31+488.69	29		0.25	0.00	500	490.63	245.69	0.00	1.64	1.4	1.2	1.68	0.79	0.718	0.28	0.55	1.17	0.89		H
T1649	31+510.78		-3.3	0.00	-0.03	500	490.63	0.00	-28.25		1.40	2.05	2.87	0.84				1.46	1.36	0.51	V2
T1650	31+534.09	9		0.08	0.00	500	490.63	76.99	0.00	0.51	0.9	1.2	1.08	0.89	0.570	0.43	0.68	0.95	0.57		H
T1655	31+694.30	19		0.17	0.00	500	490.63	161.95	0.00	1.08	0.9	1.2	1.08	0.85	0.647	0.35	0.5	0.84	0.53		H

TABELA ANKER BLOKOVA OD ODVOJKA BUSOVAČA DO REZERVOARA PUTOVIĆI

Tjeme	Stacionaža	α -hor	α -ver	$\sin(\alpha$ -hor/2)	$\sin(\alpha$ -ver)/2	ϕ (mm)	N (kN)	$R = 2 * N * \sin(\alpha$ -hor)/2 (kN)	$R = 2 * N * \sin(\alpha$ -ver)/2 (kN)	potA= R/ σ (m2)	Usvojena dužina (A)	Usvojena širina (V)/visina (H) = (B)	Usvojena površina axb	a'	x	y	a''	Vbr	V m3	L	Tip bloka
T1657/P1270	31+751.75	13		0.11	0.00	500	490.63	111.08	0.00	0.74	0.9	1.2	1.08	0.88	0.601	0.40	0.6	0.90	0.55		H
T1660/P1274	31+851.80	22		0.19	0.00	500	490.63	187.23	0.00	1.25	1.1	1.2	1.32	0.83	0.669	0.33	0.55	0.99	0.68		H
T1661	31+870.55	14		0.12	0.00	500	490.63	119.59	0.00	0.80	0.9	1.2	1.08	0.87	0.609	0.39	0.58	0.89	0.55		H
T1662/P1276	31+901.08		-6.7	0.00	-0.06	500	490.63	0.00	-57.34		1.40	2.05	2.87	1.20				2.96	2.76	1.03	V2
T1663	31+921.00	11		0.10	0.00	500	490.63	94.05	0.00	0.63	0.9	1.2	1.08	0.88	0.586	0.41	0.64	0.92	0.56		H
T1664	31+935.84		-4.8	0.00	-0.04	500	490.63	0.00	-41.09		1.40	2.05	2.87	1.02				2.13	1.98	0.74	V2
T1665/P1280	32+001.19		-31.9	0.00	-0.27	500	490.63	0.00	-269.65		2.56	2.05	5.25	2.56				13.45	12.95	2.56	V2
T1666	32+005.96		37.4	0.00	0.32	500	490.63	0.00	314.60	2.10	1.8	1.2	2.16	0.71	0.77	0.00	0	0.00	1.17		V1
T1667	32+015.63		16.5	0.00	0.14	500	490.63	0.00	140.80	0.94	0.9	1.2	1.08	0.86	0.63	0.00	0	0.00	0.66		V1
T1668	32+032.34	45		0.38	0.00	500	490.63	375.51	0.00	2.50	2.1	1.2	2.52	0.64	0.818	0.18	0.47	1.54	1.31		H
T1669	32+034.33		-16.8	0.00	-0.15	500	490.63	0.00	-143.35		1.88	2.05	3.86	1.88				7.26	6.89	1.88	V2
T1670	32+041.21	86		0.68	0.00	500	490.63	669.22	0.00	4.46	3.8	1.2	4.56	0.06	0.949	0.05	0.21	2.41	2.23		H
T1676	32+230.10	25		0.22	0.00	500	490.63	212.38	0.00	1.42	1.2	1.2	1.44	0.82	0.690	0.31	0.54	1.04	0.75		H
T1678	32+248.24		-7.2	0.00	-0.06	500	490.63	0.00	-61.61		1.40	2.05	2.87	1.24				3.18	2.96	1.11	V2
T1681/P1292	32+298.88	19		0.17	0.00	500	490.63	161.95	0.00	1.08	0.9	1.2	1.08	0.85	0.647	0.35	0.5	0.84	0.53		H
T1683	32+334.55	22		0.19	0.00	500	490.63	187.23	0.00	1.25	1.1	1.2	1.32	0.83	0.669	0.33	0.55	0.99	0.68		H
T1691	32+506.99	73		0.59	0.00	500	490.63	583.68	0.00	3.89	3.3	1.2	3.96	0.26	0.930	0.07	0.25	2.13	1.95		H
T1692	32+510.91	14		0.12	0.00	500	490.63	119.59	0.00	0.80	0.9	1.2	1.08	0.87	0.609	0.39	0.58	0.89	0.55		H
T1693	32+518.66		13.1	0.00	0.11	500	490.63	0.00	111.93	0.75	0.9	1.2	1.08	0.88	0.60	0.00	0	0.00	0.64		V1
T1695	32+618.09	64		0.53	0.00	500	490.63	519.99	0.00	3.47	2.9	1.2	3.48	0.39	0.904	0.10	0.31	1.93		2	Prostorni
			-19.1	0.00	-0.17	500	490.63	0.00	-162.80		2.00	2.05	4.10	2.00				8.21	7.82		
T1697	32+735.24	36		0.31	0.00	500	490.63	303.23	0.00	2.02	1.7	1.2	2.04	0.73	0.765	0.24	0.53	1.34	1.08		Prostorni
			3.6	0.00	0.03	500	490.63	0.00	30.82	0.21	0.9	1.2	1.08	0.90	0.53	0.00	0	0.00			
T1698	32+746.62		-9.1	0.00	-0.08	500	490.63	0.00	-77.84		1.40	2.05	2.87	1.40				4.01	3.74	1.4	V2
T1699	32+768.27	81		0.65	0.00	500	490.63	637.28	0.00	4.25	3.6	1.2	4.32	0.14	0.944	0.06	0.22	2.29	2.11		H
T700	32+779.35		26.6	0.00	0.23	500	490.63	0.00	225.74	1.50	1.3	1.2	1.56	0.80	0.70	0.00	0	0.00	0.89		V1
Ukupno:																			520.93		